

## Questions and Answers

### Rooftop Air Handling Units Replacement MMS and MHS

1) Question: Matthew Bell, Eckhardt & Johnson

On drawing M2.1 it states the contractor shall install OSHA safety rails if the unit is within ten feet from the edge of the roof. Well the unit is within 10' of the edge of the roof. Are the safety rails to be temporary while we are doing the work or permanent. If they are to be permanent can you provide a make and model of what the owner wants. I just want to make sure they are happy with what they get aesthetically.

1) Answer: Bill Cooper

The rails will be temporary while the units are being installed and started up.