

MILFORD SCHOOL DISTRICT

SAU 40
100 West Street
Milford, NH 03055
603-673-2202
Fax 603-673-2237

Michael Tenters
Director of Curriculum & Instruction

Dr. Jessica Huizenga
Superintendent of Schools

Jane Fortson, CPA
Business Administrator

Dear Parents and Guardians,

In February 2018 the State of New Hampshire adopted [Senate Bill 247](#) "Preventing Childhood Lead Poisoning from Paint and Water". This bill requires that by July 1, 2019 all schools and licensed childcare facilities in the state complete testing for lead in drinking water at all locations where water is available for consumption by children. It also requires clearer real estate disclosures for homes built prior to 1978 due to the fact that lead paint was widely used before this date. To further protect your family from potential exposure, the state recommends that all residents test for lead paint if your home was built prior to 1978, and to test your water for stagnant lead from your home plumbing whether you have town water or a private well.

The water testing protocol for [Senate Bill 247 \(SB247\)](#) consists of collecting one liter of water from each fixture first thing in the morning, before there is any water use in the building. This is referred to as "stagnant lead" and is intended to represent worst case conditions. Lead is not naturally occurring in water but can leach out of plumbing fixtures as the water sits stagnant over long periods of time. This is why, in addition to testing, it is important to flush the tap every day until the water runs cold before using it for drinking or cooking.

In compliance with SB247 we have recently completed testing of all locations at which children obtain drinking water at each of the School Districts Buildings. Most locations showed levels well below the drinking water lead advisory, however, **13 sinks across the district** were found to have elevated levels. These locations were immediately taken out of service and will remain out of service until the fixtures are corrected and testing indicates that lead is below the action level. While the ultimate goal is for zero lead exposure, the action level in drinking water is currently set at 15 parts per billion (ppb) or 0.015 milligrams per liter (mg/L) as the threshold to implement remedial actions.

Testing results for The Milford School District were obtained as follows:

Test Location	Sample Date	Lab Report Date	Stagnant Lead, ppb (mg/L)
1. Heron Pond	Dec. 29, 2018	Feb. 25, 2019	3.0 ppb (0.003 mg/L)
2. Milford High School	Dec. 28, 2018	Mar. 5, 2019	4.0 ppb (0.004 mg/L)
3. Bales	Dec. 28, 2018	Jan. 28, 2019	4.0 ppb (0.004 mg/L)
4. Jacques	Dec. 28, 2018	Jan. 28, 2019	<3.0 ppb (<0.003 mg/L)
5. Milford Middle School	Dec. 29, 2018	Jan. 29, 2019	3.0 ppb (0.003 mg/L)

We are available to answer any questions and provide any additional information you may need. Please contact William Cooper, Director of Buildings and Grounds at Bill.Cooper@Milfordk12.org. In addition, the state has additional background information and resources available that you can find with a simple web search for "[NHDES Lead in Drinking Water](#)"